

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

—
VAN AMBATIELOS

PRESIDENT

E. FELICIA BRANNON
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ

—

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY

201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

—

RAYMOND S. CHAN, C.E., S.E.

GENERAL MANAGER

FRANK BUSH

EXECUTIVE OFFICER

—

MSW Canadian Plastics, Inc
140 Minto Road
Palmerston, ON N0G 2P0

Attn: Joel Koops
(519) 417-1000

RESEARCH REPORT: RR 26036
(CSI # 09770)

Expires: March 1, 2017
Issued Date: March 1, 2016
Code: 2014 LABC

GENERAL APPROVAL - Trusscore PVC Wall and Ceiling Panel

DETAILS

Trusscore PVC Wall and Ceiling Panel is a 100% virgin PVC extruded product intended for the use as wall and ceiling liner panel. It carries a limited lifetime warranty and is manufactured in standard and custom lengths. Trusscore installations include food processing, food storage, commercial kitchens, agricultural buildings, garages, and many more applications where an easy to clean, bacteria free, bright white finish is required.

The Trusscore PVC Wall and Ceiling Panel has flame spread and smoke density indexes of 10 and 400, respectively, when tested in accordance with ASTM E84. The panels are classified as Class A for interior wall and ceiling finish materials per section 803.1.1 of the 2014 Los Angeles Building Code.

The approval is subject to the following conditions:

1. The products shall be delivered to the job site properly identified with the manufacturer's name and trade name of the products.
2. The Trusscore PVC Wall and Ceiling Panels are approved for use as interior plastic veneer in accordance with Section 2605 of the 2014 Los Angeles Building Code.
3. Except as specified herein, application of the system shall be in accordance with the manufacturer's instructions. A copy of the instructions shall be available at each job site.

RR 26036
Page 1 of 2

MSW Canadian Plastics, Inc.
RE: Trusscore PVC Wall and Ceiling Panel

DISCUSSION

The report is in compliance with the 2014 Los Angeles City Building Code.

The approval is based on the requirements of Section 2605 of the 2014 Los Angeles City Building Code, and tests conducted in accordance with ASTM E-84 on the finished panels.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this department has determined that all conditions of this approval have been met in the project in which it is to be used.

QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

DE
RR25898./MSWord2010
R02/15/16
TLB1600008
5D2/2603/803

Attachment: Panel Connection Details (2 Pages)